

TFI Report 490597-03

Classification

of the Reaction to Fire according to EN 13501-1:2010

Customer

Rephouse (M) SDN BHD
Jalan Jasmine 3
48300 Rawang Sel
MALAYSIA

Product

resilient floor covering
Neoflex PLANX Series Rubber Flooring

This report includes 4 pages and 0 annex(es).

Responsible at TFI

Dipl.-Ing. Ulrike Balg
senior engineer fire testing
Tel: +49 241 9679 133
u.balg@tfi-aachen.de

Aachen, 21 June 2019



Dr. Bayram Aslan

The present document is provided with an advanced electronic signature.

This report only applies to the tested samples and has been established to the best of our knowledge. Only the entire report shall be reproduced. Under no circumstances, extracts shall be used. Furthermore, we apply the "General Terms and Conditions for the Execution of Contracts" of the TFI Aachen GmbH, also with regard to the order execution.



1 Transaction

Test order	Classification of the reaction to fire according to EN 13501-1:2010
Order date	02 May 2019, 24 May 2019
Your reference	M. Brinkers
Product designation(s)	Neoflex PLANX Series Rubber Flooring
TFI sample number	19-05-0034

2 Product specification

The construction product is completely described in the test report mentioned under item 3. The test report provides the basis for the present classification

3 Results

3.1 Test reports and test results used for the classification

Test laboratory	Customer	Test report no.	Test method
TFI Aachen GmbH	Rephouse (M) SDN BHD	490597-02 dated 21 June 2019	EN ISO 9239-1:2010
			EN ISO 11925-2:2010 (15 s ignition time)

3.2 Test results

	Test method	Parameter	Number of tests	Result	
				Mean value	Requirements fulfilled (Y/N)
Product	EN ISO 9239-1:2010	Average critical heat flux [kW/m ²]	3	7.3	
		Integrated smoke value [% x min.]		215	
	EN ISO 11925-2:2010	Flame tip < 150 mm	6	-	Y

3.3 Classification and field of application

The construction product "Neoflex PLANX Series Rubber Flooring" is classified as follows with regard to the reaction to fire:

C_{fi}

The additional classification with regard to the smoke development is:

s1

The additional classification with regard to burning droplets/particles is:

-

The format of the reaction to fire classification for floor coverings is:

Reaction to fire		Smoke development	
C_{fi}	-	s	1

Classification of the reaction to fire: C_{fi} - s1

**This classification is valid for the following end use application:**

Type of end use application	flooring
Substrate	noncombustible substrates (Euroclass A1 and A2-s1,d0) with a gross density $\geq 1350 \text{ kg/m}^3$
Underlay for installation	no
Type of fixation	glued or unglued
Joint according to EN ISO 9239-1:2010	no

Limitations

This classification document does not represent any type approval or certification of the product.