

Emission Test Certificate

Friday, 19th December 2014

Supplier: Gerflor Australasia (17 Cato Street, Hawthorn East, VIC 3123)

Sample Description: Mipolam Ambiance Ultra (Evercare)

Date Tested: December 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p align="center">Green Building Council of Australia Green Star Office Design v3 IEQ-13</p>	<p align="center">Mipolam Ambiance Ultra (Evercare)</p>
<p align="center">Total Volatile Organic Compound Emission Rate limit <0.5mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.101mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV141203