

Emission Test Certificate

Tuesday 02nd April 2019

Supplier: Gerflor Australasia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123, Australia)

Sample Description: Gerflor Tarasafe Ultra/Gerflor Tarasafe Geo

Date Tested: March 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p align="center">Green Building Council of Australia Green Star Design & As Built v1.1 - 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B</p>	<p align="center">Gerflor Tarasafe Ultra/Gerflor Tarasafe Geo</p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.188 mg/m²/hr</p>
<p align="center">Formaldehyde Emission Rate Limit: ≤0.1 mg/m²/hr</p>	<p align="center">Formaldehyde Emission Rate: <0.005 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

CV190328