

Emission Test Certificate

Monday, 24th February 2020

Supplier: Gerflor Australia Pty Ltd (17 Cato Street, Hawthorn East, VIC, 3123, Australia)

Sample Description: NERA WOOD Vinyl Flooring

Date Tested: February 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 Hours):

<p align="center">Green Building Council of Australia Green Star Design & As Built v1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center">NERA WOOD Vinyl Flooring</p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.013 mg/m²/hr</p>
<p align="center">Formaldehyde Emission Rate Limit: ≤0.1 mg/m²/hr</p>	<p align="center">Formaldehyde Emission Rate: 0.006 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dale Duncan
BSc (Hons)
Consultant



Dr. Tuan Duong
BEng (Chemical)
Senior Consultant

V2002016A